




Recirculating Cooler

SRC14

Instructions for use






Fig.1

Recirculating Cooler SRC14

Instructions for use

Introduction

Thank you for purchasing this piece of Stuart equipment. To get the best performance from the equipment and for your own safety, please read these instructions carefully before use. Before discarding the packaging check that all parts are present and correct.

This equipment is designed to operate under the following conditions:

- For indoor use only
- Use in a well ventilated area
- Ambient temperature range +5°C to +35°C
- Altitude to 2000m
- Relative humidity not exceeding 80%
- Mains supply fluctuation not exceeding 10%
- Over-voltage category II IEC60364-4-443
- Pollution degree 2

If the equipment is not used in the manner described in this manual and with accessories other than those recommended by Stuart, the protection provided may be impaired.

Electrical Installation

 **THIS EQUIPMENT MUST BE EARTHED**

Before connection please ensure that the line supply corresponds to that shown on the rating plate. This model requires a supply rated at 220 - 240V, 50 Hz, ~, single phase.

Model	Supply requirements	Power
SRC14	230V, 50 Hz,	1.1kW

There is an IEC socket at the rear of the instrument for connection to the mains supply. The unit is supplied with two mains leads fitted with IEC plugs for connection to the instrument. One has a UK 3 pin plug and the other has a 2 pin "Shuko" plug for connection to the mains. Choose the lead appropriate for your electrical installation and discard the other. Should neither lead be suitable, take the lead with the UK plug and replace the plug with a suitable alternative. See the enclosed instruction sheet for advice on how to carry out this procedure. Should the mains lead require replacement a cable of 1mm² of harmonised code H05W-F connected to an IEC 320 plug should be used.

THIS OPERATION SHOULD ONLY BE UNDERTAKEN BY A QUALIFIED ELECTRICIAN

The appropriate mains lead should be connected **BEFORE** connection to the mains supply.

General Description

The SRC14 accurately controls the temperature of a cooling liquid between -20 to +30°C. The cooled liquid is then circulated to an external device via the inlet and outlet nozzle. The SRC14 has a capacity of 14 litres.

Safety Advice Before Use

- Beware some cooling mediums are ignitable above ambient temperatures, do not use with hazardous materials or liquids.
- Never move or carry the unit when in use or connected to the mains electricity supply.
- Please take care not to touch the cooling elements under the air filter, as these can be sharp.
- Do not place anything on top of the unit during operation

Installation

Position your recirculating cooler on a firm level surface. A byproduct of the air cooled refrigeration unit is heat, unnecessary heat build up can lower the cooling performance of the unit. To avoid this please ensure the unit is located in a well ventilated area. The unit should not be exposed to direct sunlight, humidity, dust or vibration. For optimum performance the following clearance should be allowed: 20cm from both sides, 60cm above the unit and 40cm behind. Do not obstruct the front ventilation on either unit.

Care should be taken not to tilt the SRC14 by more than 45 degrees when moving. Ensure that the castors on the SRC14 are locked prior to use (only the front 2 castors have stoppers).

Operation

Connection of hoses:

Connect the 90° elbows to the nozzles then connect the elbow adapters including flow control valve (Fig. 2) Connect suitable tubing (ID 9mm) to each nozzle (inlet and outlet)

NOTE: Take care not to use excessive force connecting the hoses, use universal clips or similar to secure the tubing if necessary. Always consider the temperature and pressure requirements before selecting your tubing material. Use tubing of the minimum length required, excessively long tubing will reduce the efficiency of the unit.




Fig.2

Filling procedure:

When choosing your cooling medium you should take care that there is no risk of corrosion of internal parts, these include the following materials; copper, stainless steel, brass, PTFE, polyacetal resin, silicone rubber, polypropylene oxide and ethylene propylene rubber. Distilled water should also be avoided as it could dissolve metal substances in the circulation line. For operation below +7°C it is recommended that ethylene glycol is used as your cooling medium. Prior to filling the unit make sure that the drain stopper is in place. Pour 14 litres of your cooling medium into the circulation tank, or until the liquid level is approximately 2 cm from the top of the tank, take care not to overflow. Replace the circulation tank cover.

Operation

Connect the power lead to the IEC connector at the back of the unit. Make sure that the power switch and pump switch are in the off position on the control panel (Fig. 3) then connect the power cable to the mains supply. Turn the power switch on the main control panel to the on position. The display will show the current temperature of the cooling medium. The refrigeration unit will automatically start if the current temperature is 0.5°C higher than the set temperature (the temperature is set to 20°C before shipment). The refrigerator must be switched on manually using the switch on the control panel, once on, it will automatically cut in and out to control the temperature of the cooling medium.




Fig.3

Setting the temperature:

To set the temperature of the cooling medium press the SET key once, the display will change from the current temperature to the set temperature (blinking) use the up and down keys to reach your desired value, hold down either key to scroll the temperature. After reaching the desired value press the set key again, the display will revert to the current temperature. If the SET key is pressed once and no other key is pressed for five seconds the display will automatically revert to the current temperature. The set temperature is retained in the memory when mains power is switched off. The refrigerator must be switched on manually using the switch on the control panel, once on it will automatically cut in and out to control, the temperature of the cooling medium.

Adjustment of flow rate:

Use the flow rate valve on the outlet nozzle to adjust the flow rate. Operation of the pump with this valve close could damage the pump. Take care when opening this valve; opening the valve too quickly could cause damage to the tubing or glassware in the circulation line.

Calibration of display temperature:

For normal operation it is not usually necessary to calibrate the temperature. Measure the temperature of the cooling liquid using a thermometer. Press the set key for more than 5 seconds. "Pb" will be displayed. Using the up and down key to select the correct value as measured on the thermometer (calibration can only be performed between +9.9°C and -9.9°C). After setting the correct value press the set key for more than 5 seconds, the display will return to the current measured temperature.

After operation:

Switch the circulation pump off, then switch off the power switch and the mains power. Place an appropriate collection vessel for the cooling medium underneath the drain hose and the drain stopper. Once all fluid has been drained replace the drain stopper.

Maintenance & Servicing

WARNING: Ensure the unit is disconnected from the mains electricity supply before attempting maintenance or servicing.

Cleaning the refrigeration air filter:

If the refrigeration air filter blocks it can affect the efficiency of the unit. Periodically this filter should be checked and cleaned. Disconnect the unit from the mains power supply. The front panel is removable: press on the two black squares in the top corners of the front panel and the panel will open. Remove the filter (fig 4). Be careful not to touch the cooling elements as these can be sharp. Shake the dust out of the filter and wash with mild detergent if necessary.

Allow the filter to air dry before replacement.




Fig.4

Cleaning of the cooling liquid filter:

The cooling liquid filter is located at the bottom of the circulation tank (fig 5). Drain the tank then remove the filter, it should easily pull free. Clean and replace.




Fig.5

General Maintenance

Periodically wipe clean the inside of the circulation tank and locate the fuse box at the rear of the unit (Fig. 6). Use mild detergent if necessary. Regularly check connections for leakage. The condition of the o-ring in the inlet and outlet nozzle should be checked periodically and replaced if necessary.

At high temperatures or high humidity water can collect in the cooling system of the SRC14, this should be drained periodically via the hose located at the back of the unit. To change the fuse on the SRC14, switch off the mains power. Insert a small screwdriver into the slot and push downwards, as shown in Fig. 7.





Fig.7



Any repairs or replacement of parts MUST be undertaken by suitably qualified personnel.

For a comprehensive list of parts required by service engineers conducting internal repairs and a service manual, please contact the Technical Service Department of Bibby Scientific Ltd. quoting both the model and serial number. Only spare parts supplied or specified by Bibby Scientific Ltd. or its agents should be used. Fitting of non-approved parts may affect the performance and safety features designed into the instrument. If in any doubt, please contact the Technical Service Department of Bibby Scientific Ltd. or the point of sale.

Bibby Scientific Ltd.
Stone, Staffordshire ST15 0SA
United Kingdom
Tel: +44 (0) 1785 812121
Fax: +44 (0) 1785 813748
e-mail equipment@bibby-scientific.com
www.bibby-scientific.com

Warranty

Bibby Scientific Ltd warrants this instrument to be free from defects in material and workmanship, when used under normal laboratory conditions, for a period of three (3) years. In the event of a justified claim Bibby Scientific will replace any defective component or replace the unit free of charge. This warranty does NOT apply if damage is caused by fire, accident, misuse, neglect, incorrect adjustment or repair, damage caused by incorrect installation, adaptation, modification, fitting of non approved parts or repair by unauthorised personnel.

Technical Specification

SRC14

Cooling capacity	1200W at 10°C
Temperature range	-20 to +30°C
Control accuracy	±2°C
Bath capacity	14 litres
Pump rate	18 litres / minute
Dimensions (w x d x h)	354 x 384 x 851mm
Net weight	41kg
Electrical supply	230V, 50Hz

Instructions for use

Note: Alarm is cleared by turning off the power switch

Problem	Cause	Solution
Cooling liquid is not circulated.	Cooling liquid filter is blocked. Air is trapped in the pump.	Clean the filter – See the Maintenance and Servicing section for details. Briefly remove the drain stopper until all trapped air has been removed.
Flow pressure is reduced.	Tubing is trapped. Pressure loss due to excessive tubing length. The circulator is too low compared to the device it is cooling.	Check the tubing isn't pinched, twisted or trapped Try to reduce the overall length of the tubing. Adjust the position of the recirculating cooler.
No refrigeration of cooling medium.	Refrigeration unit is broken. The cooling medium isn't sufficiently covering the cooling coil. Overload of refrigeration unit (alarm led illuminates)	Contact your local service representative. Top up the cooling medium. Lower ambient temperature below 35°C, or raise set temperature.
Display does not illuminate when power is on.	No mains power. Circuit breaker has tripped. Fuse has blown. Temperature controller is broken.	Check mains power supply. Unscrew maintenance panel and check switchable circuit breaker is in the on position. If problem persists there could be an electrical leakage and you should contact your local service representative. Follow procedure to change fuse in the Maintenance and services section Contact local service representative
Cooling power is poor.	Refrigeration unit does not work. The ambient temperature exceeds 35°C Exhaust is blocked. Refrigeration air filter is blocked	Contact local service representative. Try to lower the ambient temperature. Check necessary clearance around the unit has been allowed. Follow the procedure detailed in the Maintenance and Servicing section to clean the filter.
Water freezes in the circulation tank at +7°C	Loss of flow pressure	Check flow pressure, see above Use anti freeze for cooling medium.
Blinks on the display 	Temperature sensor malfunction Measured temperature is lower than the units lower limit (-50°C)	Contact local service representative.
Blinks on the display, refrigeration stops 	Temperature sensor short circuit Measured temperature exceeds the upper limit of the unit (more than +40°C)	The heating load exceeds capacity, reduce load.
Display is abnormal or unstable: 	Electrical noise causes abnormal display on temperature controller Temperature controller is reset by electrical noise Ambient temperature exceeds 35°C	Turn off mains power, wait 5 seconds then switch back on. Move unit to a new location. Lower ambient temperature below 35°C.



This product meets the applicable EC harmonized standards for radio frequency interference and may be expected not to interfere with, or be affected by, other equipment with similar qualifications. We cannot be sure that other equipment used in its vicinity will meet these standards

and so we cannot guarantee that interference will not occur in practice. Where there is a possibility that injury, damage or loss might occur if equipment malfunctions due to radio frequency interference, or for general advice before use, contact the Technical Department of Bibby Scientific Ltd.

Declaration of Conformity

Large Recirculating Cooler, Model, SRC14

These products comply with the requirements of the EU Directives listed below:

2004/108/EC **EMC Directive.**
2006/95/EC **Low voltage Directive (LVD)**

Compliance with the requirements of these Directives is claimed by meeting the following standards:

EN 61326-1:2006 (Electrical Equipment for Measurement, Control and Laboratory use).
EN 61010-1: 2001 (Safety Requirements Electrical Equipment for Measurement, Control and Laboratory use)

Compliance Certificates and Equipment Specification.

The full product specifications, listed in report number:

RETS(E)1217/A/1 (from Epsilon Technical Services)

And report numbers:

02U1562-5 and 02U1562-1A (from Compliance Certification Services)

The above certificates and reports, from an independent test house, are available upon request.

CE mark affixed '05.

Signed:  (Mr S. Marriott)

Date: 22 Nov 2010

Authority: Technical Manager
Bibby Scientific Ltd



Bibby Scientific Ltd - Stone - Staffs - ST15 0SA - UK
Tel: +44 (0) 1785 812121 - Fax +44 (0) 1785 813748

INSPECTION REPORT

MODEL SRC14

ELECTRICAL SAFETY

1. Earth continuity
2. Insulation
3. Flash test




FUNCTIONAL

1. Indicators
2. Speed/temperature
3. Visual acceptance



QUALITY CONTROL INSPECTOR



Bibby Scientific France SAS

ZI du Rocher Vert - BP 79
77793 Nemours Cedex
France
Tel: +33 1 64 45 13 13
Fax: +33 1 64 45 13 00
e-mail: bsf@bibby-scientific.fr
www.bibby-scientific.com

Bibby Scientific Italia Srl

Via Alcide de Gasperi 56
20077 Riozzo di Cerro al Lambro
Milano Italia
Tel: +39 (0)2 98230679
Fax: +39 (0)2 98230211
e-mail: marketing@bibby-scientific.it
www.bibby-scientific.it

Bibby Scientific Ltd

Beacon Road Stone
Staffordshire ST15 0SA
United Kingdom
Tel: +44 (0)1785 812121
Fax: +44 (0)1785 810471
e-mail: info@bibby-scientific.com
www.bibby-scientific.com

Bibby Scientific US Ltd

3 Terri Lane Suite 10
Burlington NJ 08016
USA
Tel: 800-225-9243
Fax: 609-589-2571
www.bibby-scientific.com

Bibby Scientific (Asia) Ltd

Room 607 Yen Sheng Centre
64 Hoi Yuen Road Kwun Tong
Kowloon Hong Kong
Tel: +852 3583 1581
Fax: +852 3583 1580
e-mail bibby@bibby-scientificasia.com
www.bibby-scientificasia.com